

时间/单位	进水COB (mg/L)	进水氨 (mg/L)
025/4/22 0:00	116.6	33.55
025/4/22 1:00	112.6	33.11
025/4/22 2:00	112.6	33.11
025/4/22 3:00	116.5	32.96
025/4/22 4:00	116.5	32.96
025/4/22 5:00	117.1	36.73

参数		进水水质					进水流量		出水水质					出水流量		进出水日累计流量	
		进水COD (mg/L)	进水氨氮 (mg/L)	进水PH	进水总磷 (mg/L)	进水总氮 (mg/L)	瞬时流量 (M3/h)	累计流量 (M3)	出水COD (mg/L)	出水氨氮 (mg/L)	出水PH	出水总磷 (mg/L)	出水总氮 (mg/L)	瞬时流量 (M3/h)	累计流量 (M3)	进水日累计 (M3)	出水日累计 (M3)
-	时间/单位																
1	2025/4/22 0:00	116.6	33.55	7.04	3.301	39.76	633	14099736	8.2	0.332	6.67	0.185	11.72	622	12557771	634	666
2	2025/4/22 1:00	112.6	33.11	7.04	3.305	39.76	633	14100370	8.1	0.266	6.75	0.18	11.72	619	12558437	634	603
3	2025/4/22 2:00	112.6	33.11	7.04	3.305	39.02	635	14101004	8.1	0.266	6.75	0.18	11.74	602	12559040	635	610
4	2025/4/22 3:00	116.5	32.96	7.06	3.331	39.02	641	14101639	7.7	0.206	6.78	0.177	11.74	631	12559650	636	616
5	2025/4/22 4:00	116.5	32.96	7.05	3.331	40.49	633	14102275	7.7	0.206	6.78	0.177	11.72	622	12560266	627	612
6	2025/4/22 5:00	117.1	36.72	7	3.837	40.49	626	14102902	7.8	0.185	6.75	0.178	11.72	416	12560878	631	608
7	2025/4/22 6:00	117.1	36.72	7.04	3.837	41.85	632	14103533	7.8	0.185	6.72	0.178	11.69	639	12561486	628	635
8	2025/4/22 7:00	144.5	40.15	7.04	3.916	41.85	626	14104161	7.6	0.138	6.72	0.172	11.71	642	12562121	629	643
9	2025/4/22 8:00	144.5	40.15	7	3.916	48.13	630	14104790	7.6	0.138	6.72	0.172	11.71	664	12562764	634	487
10	2025/4/22 9:00	153.7	36.26	6.95	3.922	48.13	641	14105424	7.7	0.096	6.72	0.173	11.71	549	12563251	625	480
11	2025/4/22 10:00	91.1	25.22	6.95	1.927	47.13	623	14106049	7.7	0.096	6.72	0.173	11.69	642	12563731	621	516
12	2025/4/22 11:00	161.3	36.04	6.92	4.322	25.18	619	14106670	7.4	0.079	6.75	0.175	11.69	588	12564247	619	570
13	2025/4/22 12:00	161.3	36.04	6.89	4.322	25.18	617	14107289	20.6	1.461	6.67	0.189	8.12	532	12564817	625	554
14	2025/4/22 13:00	127.1	30.81	6.88	3.445	25.18	621	14107914	7.1	0.061	6.68	0.175	11.79	588	12565371	625	579
15	2025/4/22 14:00	127.1	30.81	6.88	3.445	39.78	628	14108539	7.1	0.061	6.72	0.175	11.79	577	12565950	626	577
16	2025/4/22 15:00	125.6	31.36	6.88	3.588	39.78	630	14109165	7.4	0.042	6.77	0.182	11.81	532	12566527	628	564
17	2025/4/22 16:00	125.6	31.36	6.92	3.588	39.58	635	14109793	7.4	0.042	6.78	0.182	11.81	517	12567091	625	494
18	2025/4/22 17:00	125.6	38.95	6.98	4.561	39.58	619	14110418	7.6	0.025	6.79	0.216	11.77	478	12567585	620	524
19	2025/4/22 18:00	100	38.95	7.03	4.561	45.64	623	14111038	0	0.025	6.79	0.216	11.77	602	12568109	624	487
20	2025/4/22 19:00	125.8	35.51	7.03	3.754	45.64	621	14111662	80	0.015	6.69	0.195	11.77	297	12568596	620	606
21	2025/4/22 20:00	115.5	35.51	7.03	3.754	44.66	626	14112282	80	0.015	6.74	0.195	11.78	608	12569202	629	597
22	2025/4/22 21:00	118.6	40.64	7.05	3.854	44.66	632	14112911	6.5	0.007	6.72	0.2	11.72	585	12569799	630	590
23	2025/4/22 22:00	118.6	40.64	7.03	3.854	45.08	633	14113541	6.5	0.007	6.69	0.2	11.72	605	12570389	632	621
24	2025/4/22 23:00	102.4	33.27	7.03	3.199	45.08	626	14114173	6.8	0.004	6.69	0.201	11.72	506	12571010	631	610
25	平均值	124.05	35.033	6.99	3.674	40.444	628	14106970	13.77	0.165	6.73	0.185	11.589	569	12564504	628	577
26	最大值	161.3	40.64	7.06	4.561	48.13	641	14114173	80	1.461	6.79	0.216	11.81	664	12571010	636	666
27	最小值	91.1	25.22	6.88	1.927	25.18	617	14099736	0	0.004	6.67	0.172	8.12	297	12557771	619	480
28	累计值															15068	13849

参数	进水COD	进水
时间/单位	(mg/L)	(m
25/4/22 0:00	116.6	38
25/4/22 1:00	112.6	33
25/4/22 2:00	112.6	38

参数		进水质					进水量		出水水质					出水量		进出水日累计流量	
		进水COD	进水氨氮	进水PH	进水总磷	进水总氮	瞬时流量	累计流量	出水COD	出水氨氮	出水PH	出水总磷	出水总氮	瞬时流量	累计流量	进水日累计	出水日累计
	时间/单位	(mg/L)	(mg/L)		(mg/L)	(mg/L)	(M3/h)	(M3)	(mg/L)	(mg/L)		(mg/L)	(mg/L)	(M3/h)	(M3)	(M3)	(M3)
1	2025/4/22 0:00	116.6	33.55	7.04	3.301	39.76	633	14099736	8.2	0.332	6.67	0.185	11.72	622	12557771	634	666
2	2025/4/22 1:00	112.6	33.11	7.04	3.305	39.76	633	14100370	8.1	0.266	6.75	0.18	11.72	619	12558437	634	603
3	2025/4/22 2:00	112.6	33.11	7.04	3.305	39.02	635	14101004	8.1	0.266	6.75	0.18	11.74	602	12559040	635	610
4	2025/4/22 3:00	116.5	32.96	7.06	3.331	39.02	641	14101639	7.7	0.206	6.78	0.177	11.74	631	12559650	636	616
5	2025/4/22 4:00	116.5	32.96	7.05	3.331	40.49	633	14102275	7.7	0.206	6.78	0.177	11.72	622	12560266	627	612
6	2025/4/22 5:00	117.1	36.72	7	3.837	40.49	626	14102902	7.8	0.185	6.75	0.178	11.72	416	12560878	631	608
7	2025/4/22 6:00	117.1	36.72	7.04	3.837	41.85	632	14103533	7.8	0.185	6.72	0.178	11.69	639	12561486	628	635
8	2025/4/22 7:00	144.5	40.15	7.04	3.916	41.85	626	14104161	7.6	0.138	6.72	0.172	11.71	642	12562121	629	643
9	2025/4/22 8:00	144.5	40.15	7	3.916	48.13	630	14104790	7.6	0.138	6.72	0.172	11.71	664	12562764	634	487
10	2025/4/22 9:00	153.7	36.26	6.95	3.922	48.13	641	14105424	7.7	0.096	6.72	0.173	11.71	549	12563251	625	480
11	2025/4/22 10:00	91.1	25.22	6.95	1.927	47.13	623	14106049	7.7	0.096	6.72	0.173	11.69	642	12563731	621	516
12	2025/4/22 11:00	161.3	36.04	6.92	4.322	25.18	619	14106670	7.4	0.079	6.75	0.175	11.69	588	12564247	619	570
13	2025/4/22 12:00	161.3	36.04	6.89	4.322	25.18	617	14107289	20.6	1.461	6.67	0.189	8.12	532	12564817	625	554
14	2025/4/22 13:00	127.1	30.81	6.88	3.445	25.18	621	14107914	7.1	0.061	6.68	0.175	11.79	588	12565371	625	579
15	2025/4/22 14:00	127.1	30.81	6.88	3.445	39.78	628	14108539	7.1	0.061	6.72	0.175	11.79	577	12565950	626	577
16	2025/4/22 15:00	125.6	31.36	6.88	3.588	39.78	630	14109165	7.4	0.042	6.77	0.182	11.81	532	12566527	628	564
17	2025/4/22 16:00	125.6	31.36	6.92	3.588	39.58	635	14109793	7.4	0.042	6.78	0.182	11.81	517	12567091	625	494
18	2025/4/22 17:00	125.6	38.95	6.98	4.561	39.58	619	14110418	7.6	0.025	6.79	0.216	11.77	478	12567585	620	524
19	2025/4/22 18:00	100	38.95	7.03	4.561	45.64	623	14111038	0	0.025	6.79	0.216	11.77	602	12568109	624	487
20	2025/4/22 19:00	125.8	35.51	7.03	3.754	45.64	621	14111662	80	0.015	6.69	0.195	11.77	297	12568596	620	606
21	2025/4/22 20:00	115.5	35.51	7.03	3.754	44.66	626	14112282	80	0.015	6.74	0.195	11.78	608	12569202	629	597
22	2025/4/22 21:00	118.6	40.64	7.05	3.854	44.66	632	14112911	6.5	0.007	6.72	0.2	11.72	585	12569799	630	590
23	2025/4/22 22:00	118.6	40.64	7.03	3.854	45.08	633	14113541	6.5	0.007	6.69	0.2	11.72	605	12570389	632	621
24	2025/4/22 23:00	102.4	33.27	7.03	3.199	45.08	626	14114173	6.8	0.004	6.69	0.201	11.72	506	12571010	631	610
25	平均值	124.05	35.033	6.99	3.674	40.444	628	14106970	13.77	0.165	6.73	0.185	11.589	569	12564504	628	577
26	最大值	161.3	40.64	7.06	4.561	48.13	641	14114173	80	1.461	6.79	0.216	11.81	664	12571010	636	666
27	最小值	91.1	25.22	6.88	1.927	25.18	617	14099736	0	0.004	6.67	0.172	8.12	297	12557771	619	480
28	累计值															15068	13849

时间/单位	(mg/L)
2025/4/24 0:00	119.4
2025/4/24 1:00	97.1
2025/4/24 2:00	97.1
2025/4/24 3:00	101.3
2025/4/24 4:00	101.3

参数		进水水质					进水流量		出水水质					出水流量		进出水日累计流量	
		进水COD (mg/L)	进水氨氮 (mg/L)	进水PH	进水总磷 (mg/L)	进水总氮 (mg/L)	瞬时流量 (M3/h)	累计流量 (M3)	出水COD (mg/L)	出水氨氮 (mg/L)	出水PH	出水总磷 (mg/L)	出水总氮 (mg/L)	瞬时流量 (M3/h)	累计流量 (M3)	进水日累计 (M3)	出水日累计 (M3)
-	时间/单位																
1	2025/4/24 0:00	119.4	37.33	7.03	3.476	43.23	642	14129919	7.3	0.029	6.68	0.206	11.81	628	12585428	637	633
2	2025/4/24 1:00	97.1	33.08	7.05	3.007	43.23	633	14130556	7.1	0.013	6.71	0.197	11.82	591	12586061	633	613
3	2025/4/24 2:00	97.1	33.08	7.03	3.007	39.48	626	14131189	7.1	0.013	6.73	0.197	11.82	571	12586674	633	617
4	2025/4/24 3:00	101.3	32.54	7.03	3.057	39.48	641	14131822	6.8	0.021	6.76	0.198	11.75	608	12587291	636	619
5	2025/4/24 4:00	101.3	32.54	7	3.057	39.02	633	14132458	6.8	0.021	6.76	0.198	11.75	625	12587910	636	624
6	2025/4/24 5:00	104.4	32.58	7	3.247	39.02	635	14133094	7.1	0.011	6.74	0.2	11.83	616	12588534	634	597
7	2025/4/24 6:00	104.4	32.58	7	3.247	38.81	642	14133728	7.1	0.011	6.72	0.2	11.83	611	12589131	636	614
8	2025/4/24 7:00	105.3	34.39	7	3.562	38.81	633	14134364	7.2	0.009	6.7	0.194	11.79	622	12589745	634	627
9	2025/4/24 8:00	105.3	34.39	7	3.562	39.53	635	14134998	7.2	0.009	6.68	0.194	11.79	679	12590372	634	496
10	2025/4/24 9:00	136.2	35.41	7.03	3.634	39.53	624	14135632	7.1	0.006	6.67	0.189	11.78	605	12590868	629	577
11	2025/4/24 10:00	85.8	25.36	6.99	1.896	43.36	628	14136261	7.1	0.006	6.66	0.189	11.78	486	12591445	631	389
12	2025/4/24 11:00	127.9	31.66	6.99	3.427	23.86	632	14136892	7.2	0.007	6.53	0.207	11.79	243	12591834	631	558
13	2025/4/24 12:00	138.5	35.07	7.01	3.427	23.86	626	14137523	20.9	1.526	6.63	0.202	8.01	580	12592392	628	587
14	2025/4/24 13:00	136.1	35.09	6.97	3.859	41.23	633	14138151	19.6	1.537	6.65	0.202	11.84	588	12592979	632	591
15	2025/4/24 14:00	135.2	34.98	6.91	3.814	40.51	633	14138783	22.7	1.564	6.64	0.206	11.83	616	12593570	629	568
16	2025/4/24 15:00	300	35.42	6.87	3.648	41.17	630	14139412	22.9	1.565	6.65	0.203	11.81	560	12594138	632	556
17	2025/4/24 16:00	300	35.42	6.86	3.648	41.07	633	14140044	14.8	1.309	6.67	0.316	11.81	478	12594694	630	555
18	2025/4/24 17:00	124.1	36.17	7.05	3.615	40.26	632	14140674	17.9	1.568	6.67	0.323	11.56	543	12595249	633	580
19	2025/4/24 18:00	120.7	35.91	7	3.627	39.73	635	14141307	18.1	1.579	6.69	0.298	11.54	585	12595829	630	599
20	2025/4/24 19:00	121.3	34.71	6.95	3.391	39.17	630	14141937	17.9	1.591	6.71	0.33	11.54	588	12596428	630	541
21	2025/4/24 20:00	119.1	34.27	6.95	3.401	39.29	628	14142567	17.9	1.591	6.71	0.33	10.54	458	12596969	630	613
22	2025/4/24 21:00	178.2	45.83	7	4.251	39.29	623	14143197	7.2	0.318	6.69	0.244	10.55	599	12597582	629	616
23	2025/4/24 22:00	177.8	44.84	7	4.248	45.46	633	14143826	7.2	0.318	6.67	0.244	9.49	611	12598198	631	626
24	2025/4/24 23:00	175.3	45.47	7	4.329	46.01	628	14144457	10.5	0.248	6.62	0.241	9.46	631	12598824	634	626
25	平均值	125.49	35.338	6.99	3.325	39.35	632	14137200	11.78	0.62	6.68	0.229	11.313	572	12592173	632	584
26	最大值	300	45.83	7.05	4.329	46.01	642	14144457	22.9	1.591	6.76	0.33	11.84	679	12598824	637	633
27	最小值	0	25.36	6.86	0	23.86	623	14129919	6.8	0.006	6.53	0.189	8.01	243	12585428	628	389
28	累计值															15172	14022

时间/单位	进水COD (mg/L)	进水氨氮 (mg/L)	进水总磷 (mg/L)
025/4/25 0:00	175.3	4	4
025/4/25 1:00	172.4	4	4
025/4/25 2:00	172.4	4	4
025/4/25 3:00	169.3	4	4

时间/单位		进水水质					进水流量		出水水质					出水流量		进出水日累计流量	
		进水COD (mg/L)	进水氨氮 (mg/L)	进水PH	进水总磷 (mg/L)	进水总氮 (mg/L)	瞬时流量 (M3/h)	累计流量 (M3)	出水COD (mg/L)	出水氨氮 (mg/L)	出水PH	出水总磷 (mg/L)	出水总氮 (mg/L)	瞬时流量 (M3/h)	累计流量 (M3)	进水日累计 (M3)	出水日累计 (M3)
1	2025/4/25 0:00	175.3	45.47	7	4.329	46.11	641	14145091	10.5	0.248	6.6	0.241	9.46	628	12599450	633	629
2	2025/4/25 1:00	172.4	45.62	7	4.322	45.24	632	14145724	7.3	0.196	6.63	0.24	9.38	577	12600079	632	604
3	2025/4/25 2:00	172.4	45.62	7.03	4.322	44.75	630	14146356	7.3	0.196	6.66	0.24	9.38	602	12600683	632	602
4	2025/4/25 3:00	169.3	45.17	7	4.199	45.83	635	14146988	6.4	0.177	6.68	0.237	9.43	605	12601285	634	607
5	2025/4/25 4:00	169.3	45.17	6.99	4.199	45.83	635	14147622	6.4	0.177	6.67	0.237	9.43	591	12601892	633	566
6	2025/4/25 5:00	166.2	44.31	7	4.162	46.11	633	14148255	6.6	0.142	6.63	0.24	9.39	659	12602458	633	614
7	2025/4/25 6:00	166.2	44.31	7	4.162	46.05	637	14148888	6.6	0.142	6.58	0.24	9.39	565	12603072	638	601
8	2025/4/25 7:00	161.8	43.53	7	4.112	46.69	641	14149526	6.3	0.127	6.58	0.244	9.41	684	12603673	647	763
9	2025/4/25 8:00	161.8	43.53	7.06	4.112	46.55	644	14150173	6.3	0.127	6.56	0.244	9.41	653	12604436	635	594
10	2025/4/25 9:00	159.1	43.24	7.01	3.958	46.55	623	14150808	6.2	0.093	6.57	0.237	9.38	577	12605030	623	438
11	2025/4/25 10:00	95.3	24.49	7.05	1.881	68.13	626	14151431	6.2	0.093	6.6	0.237	9.38	483	12605468	658	586
12	2025/4/25 11:00	225.1	20.52	7.1	2.876	26.61	648	14152089	5.9	0.081	6.59	0.319	10.39	568	12606054	647	638
13	2025/4/25 12:00	225.1	20.52	7.05	2.876	26.61	637	14152736	22.9	1.497	6.59	0.187	8.06	622	12606692	657	474
14	2025/4/25 13:00	159.7	18.51	7.04	2.426	26.61	679	14153393	6.1	0.054	6.61	0.226	10.31	362	12607166	593	351
15	2025/4/25 14:00	159.7	18.51	7	2.426	29.16	536	14153986	6.1	0.054	6.6	0.226	10.31	317	12607517	560	530
16	2025/4/25 15:00	159.7	18.51	7	2.426	29.16	560	14154546	6.1	0.054	6.6	0.226	10.31	575	12608077	550	562
17	2025/4/25 17:00	83.1	5.74	6.9	0.879	28.71	595	14155860	50	0.034	6.6	0.218	10.31	602	12608873	679	676
18	2025/4/25 18:00	83.1	5.74	6.9	0.879	10.54	644	14156539	6.7	0.034	6.62	0.218	10.31	673	12609549	649	588
19	2025/4/25 19:00	77.7	3.61	6.9	1.086	10.54	648	14157188	6.8	0.029	6.65	0.238	11.71	744	12610137	640	667
20	2025/4/25 20:00	77.7	3.61	6.94	1.086	11.82	633	14157828	6.8	0.029	6.62	0.238	11.71	639	12610804	633	637
21	2025/4/25 21:00	75.2	5.32	6.94	1.404	11.82	624	14158461	6.9	0.027	6.64	0.234	11.71	647	12611441	632	655
22	2025/4/25 22:00	75.2	5.32	6.94	1.404	12.64	633	14159093	6.9	0.027	6.61	0.234	8.61	667	12612096	633	657
23	2025/4/25 23:00	70.5	4.07	6.91	1.131	12.64	635	14159726	6.8	0.026	6.61	0.256	8.58	670	12612753	634	658
24	平均值	140.05	26.451	6.99	2.829	33.434	631	14152171	9.45	0.164	6.61	0.238	9.793	597	12605937	638	600
25	最大值	225.1	45.62	7.1	4.329	68.13	679	14159726	50	1.497	6.68	0.319	11.71	744	12612753	679	763
26	最小值	70.5	3.61	6.9	0.879	10.54	536	14145091	5.9	0.026	6.56	0.187	8.06	317	12599450	593	351
27	累计值															13395	12605

时间/单位	进水COD (mg/L)	进水氨氮 (mg/L)
25/4/26 9:00	70.5	4.0
25/4/26 11:00	38.3	6.6
25/4/26 2:00	33.3	6.6
25/4/26 3:00	31.5	6.7

参数		进水水质					进水量		出水水质					出水量		进出水日累计流量	
		进水COD	进水氨氮	进水PH	进水总磷	进水总氮	瞬时流量	累计流量	出水COD	出水氨氮	出水PH	出水总磷	出水总氮	瞬时流量	累计流量	进水日累计	出水日累计
-	时间/单位	(mg/L)	(mg/L)		(mg/L)	(mg/L)	(M3/h)	(M3)	(mg/L)	(mg/L)		(mg/L)	(mg/L)	(M3/h)	(M3)	(M3)	(M3)
1	2025/4/26 0:00	70.5	4.07	6.9	1.131	10.75	626	14160360	6.8	0.026	6.62	0.256	8.58	645	12613411	631	653
2	2025/4/26 1:00	38.8	6.61	6.91	0.765	10.75	637	14160991	6.6	0.025	6.62	0.215	8.51	645	12614064	637	646
3	2025/4/26 2:00	33.3	6.61	6.9	0.765	10.72	630	14161628	6.6	0.025	6.62	0.215	8.51	642	12614710	631	641
4	2025/4/26 3:00	31.5	6.78	6.91	0.604	10.72	623	14162259	6.7	0.023	6.61	0.217	8.48	659	12615351	626	640
5	2025/4/26 4:00	31.5	6.78	6.9	0.604	10.31	633	14162885	6.7	0.023	6.6	0.217	8.48	639	12615991	624	587
6	2025/4/26 5:00	29.6	6.71	6.94	0.578	10.31	619	14163509	6.6	0.024	6.56	0.214	8.46	498	12616578	625	642
7	2025/4/26 6:00	29.6	6.71	6.94	0.578	9.95	630	14164134	6.6	0.024	6.52	0.214	8.46	622	12617220	610	631
8	2025/4/26 7:00	26.6	6.39	6.94	0.618	9.91	611	14164694	7.1	0.023	6.45	0.215	8.48	555	12617782	622	610
9	2025/4/26 8:00	26.6	6.39	6.94	0.618	9.91	624	14165389	7.1	0.023	6.45	0.215	8.48	645	12618485	480	483
10	2025/4/26 9:00	49.3	10.85	6.94	0.993	9.91	470	14165869	6.4	0.024	6.46	0.217	8.49	472	12618968	481	426
11	2025/4/26 10:00	92.5	25.54	6.84	1.876	14.84	456	14166350	6.4	0.024	6.41	0.217	8.49	317	12619394	495	349
12	2025/4/26 11:00	701.3	37.85	6.78	5.725	26.01	490	14166845	6.6	0.025	6.48	0.218	8.51	385	12619743	560	380
13	2025/4/26 12:00	701.3	37.85	6.78	5.725	26.01	693	14167405	27.5	1.507	6.45	0.183	8.01	498	12620123	676	629
14	2025/4/26 13:00	129.8	16.79	6.88	2.107	26.01	673	14168081	6.8	0.021	6.41	0.218	8.59	647	12620752	667	634
15	2025/4/26 14:00	129.8	16.79	6.89	2.107	27.59	670	14168748	6.8	0.021	6.3	0.218	8.59	619	12621386	674	628
16	2025/4/26 15:00	401.3	23.51	6.88	4.468	27.59	668	14169422	6.4	0.017	6.26	0.217	8.46	622	12622014	672	659
17	2025/4/26 16:00	401.3	23.51	6.89	4.468	43.32	675	14170094	6.4	0.017	6.29	0.217	8.46	670	12622673	673	508
18	2025/4/26 17:00	71.6	9.17	6.88	1.499	43.32	671	14170767	6.3	0.013	6.36	0.219	8.55	308	12623181	667	444
19	2025/4/26 18:00	71.6	9.17	6.89	1.499	15.15	670	14171434	6.3	0.013	6.36	0.219	8.55	681	12623625	676	681
20	2025/4/26 19:00	70.7	17.77	6.99	1.836	15.15	659	14172110	6.4	0.012	6.39	0.22	8.51	670	12624306	662	661
21	2025/4/26 20:00	70.7	17.77	6.99	1.836	22.83	664	14172772	6.4	0.012	6.36	0.22	8.51	659	12624967	656	642
22	2025/4/26 21:00	51.5	10.95	7	1.557	22.83	655	14173428	6.5	0.011	6.35	0.222	8.51	616	12625609	653	653
23	2025/4/26 22:00	51.5	10.95	7	1.557	13.69	655	14174081	6.5	0.011	6.34	0.222	8.49	664	12626262	654	657
24	2025/4/26 23:00	25.4	6.73	7	0.848	13.69	653	14174735	6.6	0.009	6.37	0.224	8.47	653	12626919	651	666
25	平均值	143.72	14.168	6.91	1.902	18.755	628	14167535	7.48	0.084	6.44	0.218	8.485	586	12620249	626	587
26	最大值	701.3	37.85	7	5.725	43.32	693	14174735	27.5	1.507	6.62	0.256	8.59	681	12626919	676	681
27	最小值	25.4	4.07	6.78	0.578	9.91	456	14160360	6.3	0.009	6.26	0.183	8.01	308	12613411	480	349
28	累计值															13771	12909



参数		进水水质					进水量		出水水质					出水量		进出水日累计流量	
		进水COD	进水氨氮	进水PH	进水总磷	进水总氮	瞬时流量	累计流量	出水COD	出水氨氮	出水PH	出水总磷	出水总氮	瞬时流量	累计流量	进水日累计	出水日累计
-	时间/单位	(mg/L)	(mg/L)		(mg/L)	(mg/L)	(M3/h)	(M3)	(mg/L)	(mg/L)		(mg/L)	(mg/L)	(M3/h)	(M3)	(M3)	(M3)
1	2025/4/27 0:00	25.4	6.73	7	0.848	10.35	637	14175386	6.6	0.009	6.39	0.224	8.47	659	12627585	641	653
2	2025/4/27 1:00	27.3	6.81	6.99	0.849	10.35	633	14176027	6.9	0.011	6.4	0.222	8.48	639	12628238	643	638
3	2025/4/27 2:00	27.3	6.81	6.99	0.849	9.38	635	14176670	6.9	0.011	6.41	0.222	8.48	616	12628876	651	639
4	2025/4/27 3:00	24.7	5.36	6.99	0.704	9.38	653	14177321	6.5	0.007	6.43	0.225	8.44	659	12629515	653	649
5	2025/4/27 4:00	24.7	5.36	7	0.704	8.04	648	14177974	6.5	0.007	6.43	0.225	8.44	650	12630164	650	647
6	2025/4/27 5:00	24.3	5.54	6.99	0.711	8.04	650	14178624	6.4	0.005	6.41	0.248	8.45	645	12630811	643	634
7	2025/4/27 6:00	24.3	5.54	6.99	0.711	7.65	641	14179267	6.4	0.005	6.42	0.248	8.45	622	12631445	644	622
8	2025/4/27 7:00	22.8	5.33	7	0.622	7.65	633	14179911	6.5	0.006	6.44	0.223	8.41	622	12632067	644	641
9	2025/4/27 8:00	22.8	5.33	6.99	0.622	9.49	650	14180555	6.5	0.006	6.4	0.223	8.41	639	12632708	649	543
10	2025/4/27 9:00	81.3	22.09	6.99	2.125	9.49	650	14181204	6.4	0.007	6.4	0.224	8.51	625	12633251	634	621
11	2025/4/27 10:00	92.9	5.11	5	1.025	25.75	632	14181838	6.4	0.203	6.5	0.189	12.42	616	12633872	636	564
12	2025/4/27 11:00	73.4	5.19	6.97	1.041	25.81	641	14182474	6.5	0.212	6.5	0.192	12.43	585	12634436	635	596
13	2025/4/27 12:00	73.4	5.38	6.95	1.036	26.04	626	14183109	27.5	1.534	6.5	0.186	8.01	622	12635032	632	625
14	2025/4/27 13:00	51.5	7.81	6.95	1.035	26.13	630	14183741	6.4	0.201	6.51	0.186	8.01	588	12635657	634	624
15	2025/4/27 14:00	51.5	7.81	6.94	1.035	26.13	633	14184375	6.4	0.201	6.51	0.201	12.38	639	12636281	633	634
16	2025/4/27 15:00	54.1	5.97	6.94	1.105	26.13	633	14185008	6.5	0.207	6.54	0.202	12.41	633	12636915	643	633
17	2025/4/27 16:00	54.1	14.28	6.95	1.934	17.11	642	14185651	6.5	4.996	6.56	0.921	24.41	639	12637548	646	635
18	2025/4/27 17:00	64.2	14.14	6.9	2.011	42.41	644	14186297	5.9	5.064	6.58	0.948	24.65	622	12638183	646	654
19	2025/4/27 18:00	64.2	14.49	6.95	2.032	42.46	646	14186943	5.9	5.138	6.59	0.964	24.66	628	12638837	649	590
20	2025/4/27 19:00	169.1	7.05	7	1.982	40.69	644	14187592	6.1	0.075	6.6	0.243	8.98	721	12639427	625	607
21	2025/4/27 20:00	169.1	7.05	6.96	1.982	12.44	628	14188217	6.1	0.075	6.62	0.243	8.98	602	12640034	623	622
22	2025/4/27 21:00	103.1	11.56	6.96	1.706	12.44	624	14188840	5.8	0.001	6.59	0.235	8.98	599	12640656	621	630
23	2025/4/27 22:00	103.1	11.56	6.96	1.706	17.21	621	14189461	5.8	0.001	6.55	0.235	8.71	628	12641286	619	620
24	2025/4/27 23:00	102.1	9.14	6.96	1.208	17.21	617	14190080	6.3	0.002	6.51	0.231	8.58	625	12641906	619	625
25	平均值	63.78	8.393	6.89	1.233	18.658	637	14182774	7.24	0.749	6.49	0.311	11.173	630	12634780	638	623
26	最大值	169.1	22.09	7	2.125	42.46	653	14190080	27.5	5.138	6.62	0.964	24.66	721	12641906	653	654
27	最小值	22.8	5.11	5	0.622	7.65	617	14175386	5.8	0.001	6.39	0.186	8.01	585	12627585	619	543
28	累计值															15313	14946

参数

参数		进水水质					进水流量		出水水质					出水流量		进出水日累计流量	
		进水COD (mg/L)	进水氨氮 (mg/L)	进水PH	进水总磷 (mg/L)	进水总氮 (mg/L)	瞬时流量 (M3/h)	累计流量 (M3)	出水COD (mg/L)	出水氨氮 (mg/L)	出水PH	出水总磷 (mg/L)	出水总氮 (mg/L)	瞬时流量 (M3/h)	累计流量 (M3)	进水日累计 (M3)	出水日累计 (M3)
-	时间/单位																
1	2025/4/28 9:00	102.3	9.14	7	1.208	11.82	621	14190699	6.3	0.002	6.51	0.231	8.58	622	12642531	619	613
2	2025/4/28 1:00	104.5	9.22	7	1.178	11.82	621	14191318	6.4	0.005	6.56	0.224	8.51	568	12643144	620	596
3	2025/4/28 2:00	104.5	9.22	7.04	1.178	15.36	617	14191938	6.4	0.005	6.56	0.224	8.51	611	12643740	620	605
4	2025/4/28 3:00	100.2	8.79	7.05	1.165	15.36	623	14192558	6.5	0.003	6.58	0.225	8.52	591	12644345	622	620
5	2025/4/28 4:00	100.2	8.79	7.04	1.165	12.81	626	14193180	6.5	0.003	6.57	0.225	8.52	625	12644965	627	613
6	2025/4/28 5:00	96.9	8.01	7.05	1.171	12.81	626	14193807	6.1	0.005	6.56	0.226	8.44	585	12645578	627	591
7	2025/4/28 6:00	96.9	8.01	7	1.171	11.91	619	14194434	6.1	0.005	6.56	0.226	8.44	588	12646169	620	613
8	2025/4/28 7:00	96.3	30.97	7	2.932	11.91	623	14195054	6.6	0.008	6.52	0.226	8.48	642	12646782	618	632
9	2025/4/28 8:00	91.4	30.97	7.01	1.871	32.73	619	14195672	26.8	1.497	6.54	0.181	7.81	631	12647414	620	488
10	2025/4/28 9:00	92.1	31.33	6.95	2.907	21.92	612	14196292	5.8	0.006	6.55	0.225	8.51	577	12647902	611	605
11	2025/4/28 10:00	92.1	25.43	6.9	2.907	21.92	612	14196903	5.8	0.006	6.53	0.225	8.51	560	12648507	604	407
12	2025/4/28 11:00	121.1	29.31	6.84	2.922	21.92	572	14197507	6.1	0	6.58	0.26	8.52	325	12648914	658	629
13	2025/4/28 12:00	121.1	29.31	6.89	2.922	37.41	666	14198165	6.1	0.147	6.55	0.26	8.52	659	12649543	669	643
14	2025/4/28 13:00	70.7	11.91	6.91	2.922	37.41	661	14198834	6.3	0.137	6.55	0.226	8.48	631	12650186	665	643
15	2025/4/28 14:00	70.7	11.91	6.9	2.922	18.81	661	14199499	6.3	0.137	6.54	0.226	8.48	647	12650829	666	592
16	2025/4/28 15:00	34.3	40	6.96	1.636	18.81	664	14200165	6.4	0.117	6.55	0.224	8.61	619	12651421	659	642
17	2025/4/28 16:00	34.3	40	6.96	1.636	10.83	655	14200824	6.4	0.117	6.55	0.224	8.61	667	12652063	660	665
18	2025/4/28 17:00	300	8.72	6.9	5	10.83	659	14201484	50	5	6.58	0.5	10	681	12652728	658	562
19	2025/4/28 18:00	300	8.72	6.97	5	40	659	14202142	50	5	6.61	0.5	10	639	12653290	659	595
20	2025/4/28 19:00	74.1	18.73	7.01	2.511	40	664	14202801	6.2	0.052	6.61	0.252	8.55	667	12653885	664	591
21	2025/4/28 20:00	74.1	18.73	7	2.511	16.91	653	14203465	6.2	0.052	6.64	0.252	8.55	684	12654476	658	681
22	2025/4/28 21:00	93.5	22.57	7	3.645	16.91	657	14204123	6.5	0.054	6.62	0.248	8.55	673	12655157	656	643
23	2025/4/28 22:00	93.5	22.57	7.01	3.645	31.17	655	14204779	6.5	0.054	6.6	0.248	8.56	673	12655800	654	675
24	2025/4/28 23:00	49.6	9.81	6.98	1.835	31.17	655	14205433	6.7	0.045	6.59	0.25	8.57	673	12656475	650	621
25	平均值	103.33	18.344	6.98	2.103	20.905	638	14197962	10.53	0.514	6.57	0.245	8.259	618	12649410	641	606
26	最大值	300	40	7.05	5	40	666	14205433	50	5	6.64	0.5	10	684	12656475	669	681
27	最小值	34.3	8.79	6.84	1.165	10.83	572	14190699	0	0	6.51	0	0	325	12642531	604	407
28	累计值															14734	13944