

巡视时间	进水数据					ORP mv		好氧池		空气流量 m³/h	风机空气压力 MPa	鼓风机频率 Hz			瞬时流量 m³/h		出水数据									
	PH	COD mg/L	氨氮 mg/L	SS mg/L	厌氧	缺氧	MLSS mg/L	DO mg/L	1#			2#	3#	进水	污泥回流	剩余污泥	出水	PH	COD mg/L	氨氮 mg/L	SS mg/L	TP mg/L	TN mg/L			
早班	1:00	0	110.2	27.28	500	-1000.0	426.3	399.6	0.4	285	0.059	0	35	0	281.7	169.8	0	244.8	6.4	13.6	0.37	1	0.185	4.5		
	3:00	0	119.4	27.88	500	-1000.0	428.2	398.2	0.4	436.6	0.059	0	35	0	283.1	169.7	0	288.7	6.4	9.5	0.39	1	0.201	4.6		
	5:00	0	146.9	28.94	500	-1000.0	429.9	398.2	0.4	600.0	0.059	0	35	0	282.7	170.5	0	254	6.4	11.5	0.43	1	0.184	5.0		
中班	7:00	0	231.4	29.33	500	-1000.0	435.4	398.2	0.4	383.2	0.059	0	35	0	138.5	167.7	0	145.4	6.4	11.1	0.52	1	0.192	4.7		
	9:00	0	166.3	27.95	500	-1000.0	438.2	411.0	0.4	600.0	0.059	0	35	0	201.9	168.1	5.2	207.0	6.4	10.3	0.57	1	0.197	4.9		
	11:00	0	178.5	26.47	500	-1000.0	443.5	405.8	0.4	234.5	0.059	0	35	0	236.4	168.7	5.1	234.6	6.4	12.0	0.43	1	0.198	4.9		
晚班	13:00	0	226.2	22.45	500	-1000.0	444.4	409.9	0.4	378.5	0.059	0	35	0	264.0	167.7	5.2	233.2	6.4	9.7	1.079	1	0.193	4.9		
	15:00	0	108.2	21.93	500	-1000.0	445.9	404.8	0.4	468.6	0.059	0	35	0	270.2	168.0	5.3	263.8	6.4	10.1	1.21	1	0.202	4.2		
	17:00	0	99.3	25.81	500	-1000.0	447.6	398.3	0.4	447.7	0.059	0	35	0	269.8	167.3	5.2	262.8	6.4	8.8	1.37	1	0.198	4.3		
统计	19:00	0	147.8	25.60	500	-1000.0	450.5	399.6	0.4	588.1	0.059	0	35	0	271.7	167.1	5.7	263.2	6.4	7.5	1.47	1	0.184	4.1		
	21:00	0	137.1	24.71	500	-1000.0	451.8	397.7	0.4	493.1	0.059	0	35	0	273.1	167.0	5.3	259.6	6.4	11.6	1.46	1	0.180	4.5		
	23:00	0	155.2	24.25	500	-1000.0	452.7	397.8	0.4	572.5	0.059	0	35	0	278.7	167.7	5.1	272.6	6.4	9.4	1.43	1	0.192	4.9		
运行情况记录		早班					1968.6					中班					晚班									
运行正常												运行正常					运行正常									
出水流量累积m³		6635945.5					5898557.9					6120.3					5932.8					400				
除磷剂用量kg																										
次氯酸钠用量kg																										

早班值班: 郭荣杰

中班值班: 谢俊

晚班值班: 李俊

审核人: 梁永斌

厂区：沙琅镇水质净化厂

天气：*晴*

2023年 11月 18日

巡视时间	进水数据					ORP mv	好氧池		空气流量 m³/h	风机空气压力 MPa	鼓风机频率 Hz			瞬时流量 m³/h			出水数据							
	PH	COD mg/L	氨氮 mg/L	SS mg/L	厌氧		缺氧	MLSS mg/L			DO mg/L	1#	2#	3#	进水	污泥回流	剩余污泥	出水	PH	COD mg/L	氨氮 mg/L	SS mg/L	TP mg/L	TN mg/L
早班	1:00	0	112.4	24.62	500	1000	41.9	1409.8	417	0.059	0	35	35	35	172.8	172.1	0	170.4	6.5	12.1	0.68	1	0.195	5.4
	3:00	0	102.4	28.44	500	1000	41.8	1407.7	465.1	0.059	0	35	35	35	171.1	171.1	0	171.3	6.5	10.8	0.73	1	0.175	5.2
	5:00	0	243.6	29.48	500	1000	44.7	1408.6	430.2	0.059	0	35	35	35	170.8	170.8	0	170.9	6.5	12.5	0.87	1	0.192	5.4
	7:00	0	160.3	29.80	500	1000	44.7	1408.1	518.3	0.059	0	35	35	35	169.8	169.8	0	169.10	6.5	11.8	1.17	1	0.204	4.4
	9:00	0	151.9	26.93	500	1000.0	47.08	1426.9	314.4	0.059	0	35	35	35	169.2	169.2	0	167.4	6.5	11.6	1.42	1	0.197	4.2
	11:00	0	201.9	27.20	500	1000.0	47.80	1424.6	526.2	0.059	0	35	35	35	170.1	170.1	0	170.1	6.6	11.1	1.51	1	0.206	3.9
	13:00	0	140.9	26.18	500	1000.0	47.2	1436.1	233.5	0.059	0	35	35	35	170.1	170.1	0	170.1	6.5	12.4	1.26	1	0.194	4.9
	15:00	0	128.7	24.30	500	1000.0	47.2	1437.0	417.2	0.059	0	35	35	35	168.3	168.3	0	167.9	6.5	10.6	0.72	1	0.210	4.2
	17:00	0	117.4	23.78	500	1000.0	47.8	1434.9	336.9	0.059	0	35	35	35	169.9	169.9	0	169.7	6.5	9.3	0.33	1	0.206	4.4
	19:00	0	110.2	22.74	500	1000.0	47.90	1433.9	263.8	0.059	0	35	35	35	167.7	167.7	0	169.6	6.5	10.8	0.11	1	0.211	4.9
	21:00	0	112.2	23.86	500	1000.0	48.4	1435.3	531.5	0.059	0	35	35	35	168.1	168.1	0	169.2	6.5	11.9	0.11	1	0.180	5.0
	23:00	0	116.3	28.47	500	1000.0	48.4	1444.5	442.0	0.059	0	35	35	35	168.3	168.3	0	170.4	6.5	10.0	0.08	1	0.168	4.9
运行情况记录	早班		123300停					1866.5		1708.3			运行正常											
运行情况记录	中班		运行正常					555.1.8		24			运行正常											
统计	进水量m³		6647742.7		5773.2		5551.8		24		除磷剂用量kg		1000		次氯酸钠用量kg									
早班值班:		123300停		中班值班:		运行正常		晚班值班:		邓荣新		审核人:		梁永新										

1区: 垃圾坝水质理化

天气: 阴

2023年11月20日

巡视时间	进水数据					ORP mv	好氧池		空气流量 m³/h	风机 空气压力 MPa	鼓风机频率 Hz			瞬时流量 m³/h			出水数据								
	PH	COD mg/L	氨氮 mg/L	SS mg/L	厌氧		MLSS mg/L	DO mg/L			1#	2#	3#	进水	污泥 回流	剩余 污泥	出水	PH	COD mg/L	氨氮 mg/L	SS mg/L	TP mg/L	TN mg/L		
早班	1:00	0	131.6	30.03	500	1000.0	480.8	4137.4	0.4	3325	0.059	0	35	0	226.4	169.0	0	228.0	6.5	12.4	0.95	1	0.169	3.9	
	3:00	0	144.7	32.20	500	1000.0	477.9	4177.7	0.4	4832	0.059	0	35	0	240.7	157.4	0	216.9	6.5	10.2	0.94	1	0.162	3.4	
	5:00	0	174.4	32.78	500	1000.0	481.8	4188.2	0.4	6000	0.059	0	35	0	191.7	158.8	0	222.3	6.5	11.2	0.96	1	0.164	3.2	
中班	7:00	0	147.8	33.15	500	1000.0	479.2	4219.5	0.4	2783	0.059	0	35	0	191.5	158.9	0	169.8	6.5	11.0	0.94	1	0.172	3.5	
	9:00	0	124.4	29.51	500	1000.0	471.0	4212.2	0.4	2248	0.059	0	35	0	232.2	157.2	5.2	194.6	6.5	11.4	0.99	1	0.174	3.7	
	11:00	0	135.7	28.53	500	1000.0	493.3	4207.5	0.4	3782	0.059	0	35	0	182.8	153.2	5.3	160.2	6.5	19.2	0.74	1	0.178	3.6	
晚班	13:00	0	130.5	27.19	500	1000.0	493.6	4191.5	0.4	6000	0.059	0	35	0	210.4	155.9	5.2	193.8	6.5	19.2	0.87	1	0.192	9.9	
	15:00	0	129.6	26.82	500	1000.0	493.1	4145.9	0.4	4776	0.059	0	35	0	230.0	156.5	5.1	191.0	6.5	24.3	0.50	1	0.161	4.4	
	17:00	0	128.7	26.76	500	1000.0	498.2	4244.7	0.4	0	0	0	35	0	200.9	137.7	0	200.4	6.6	24.3	0.22	1	0.163	4.5	
运行记录	19:00	0	143.8	26.71	500	1000.0	499.0	4406.8	0.4	3517	0.059	0	35	0	204.5	137.5	0	220.1	6.6	14.6	0.07	1	0.177	4.6	
	21:00	0	180.5	27.45	500	1000.0	502.0	4440.1	0.4	4866	0.059	0	35	0	201.7	134.1	0	204.7	6.5	17.1	0.02	1	0.150	4.7	
	23:00	0	116.2	29.01	500	1000.0	494.2	4430.0	0.4	5124	0.059	0	35	0	228.7	156.7	0	220.6	6.5	10.8	0.10	1	0.126	5.1	
早班		运行正常					1626.4		1526.7		1691		1691		1691		运行正常								
中班		运行正常					1526.7		1526.7		1526.7		1526.7		1526.7		运行正常								
晚班		运行正常					1691		1691		1691		1691		1691		运行正常								
统计		进水量m³	6657417.9	出水流量累积m³	5919359	进水量m³	5020.1	出水量m³	4844.1	进水量m³	26	除磷剂用量kg	320	次氯酸钠用量kg											

早班值班: 柳荣森

中班值班: M.M.M

晚班值班: 梁永斌

审核人: 梁永斌

厂区：沙琅镇水质净化厂

天气：晴

2022年 11 月 22 日

巡视时间	进水数据					ORP mv		好氧池		空气流量 m³/h	风机 空气 压力 MPa	鼓风机频率 Hz			瞬时流量 m³/h			出水数据					
	PH	COD mg/L	氨氮 mg/L	SS mg/L	DO mg/L	厌氧	缺氧	MLSS mg/L	DO mg/L			1#	2#	3#	进水	污泥 回流	剩余 污泥	出水	PH	COD mg/L	氨氮 mg/L	SS mg/L	TP mg/L
1:00	0	117.4	30.92	500	0.4	127.4	4157.1	0.4	2414	0.059	0	35	0	257.7	154.9	0	228.2	6.6	10.4	0.40	1	0.163	3.9
3:00	0	134.5	31.00	500	0.4	126.8	4125.7	0.4	3357	0.059	0	35	0	211.2	150.8	0	219.6	6.6	8.0	0.25	1	0.149	4.1
5:00	0	136.5	32.08	500	0.4	108.2	4377.7	0.4	2863	0.059	0	35	0	235.1	154.6	0	208.6	6.6	9.3	0.66	1	0.149	4.3
7:00	0	152.9	33.01	500	0.4	111.6	4204.4	0.4	428	0.059	0	35	0	244.9	155.1	0	140.4	6.6	8.6	0.79	1	0.166	4.1
9:00	0	180.5	28.66	500	0.4	92.2	4252.9	0.4	5830	0.059	0	35	0	107.0	156.7	5.1	112.8	6.6	11.2	0.95	1	0.158	4.2
11:00	0	159.1	25.26	500	0.4	71.8	4285.1	0.4	2755	0.059	0	35	0	202.2	157.5	5.1	201.3	6.6	11.3	1.02	1	0.165	4.2
13:00	0	180.5	27.40	500	0.4	42.7	4240.8	0.4	4902	0.059	0	35	0	202.1	159.2	5.2	189.1	6.6	11.2	1.03	1	0.193	4.2
15:00	0	138.8	27.34	500	0.4	42.3	4244.0	0.4	3214	0.059	0	35	0	206.6	154.8	5.2	187.3	6.6	10.0	0.90	1	0.142	4.2
17:00	0	131.6	31.27	500	0.4	22.1	4262.1	0.4	2835	0.059	0	35	0	205.7	156.1	5.2	178.6	6.6	8.2	0.74	1	0.142	4.1
19:00	0	128.7	32.18	500	0.4	42.2	4229.6	0.4	4320	0.059	0	35	0	218.1	155.7	5.2	176.5	6.6	7.8	0.50	1	0.143	4.0
21:00	0	158.1	31.60	500	0.4	19.1	4207.2	0.4	3721	0.059	0	35	0	244.1	175.2	5.1	264.2	6.6	9.2	0.39	1	0.141	3.8
23:00	0	129.6	30.72	500	0.4	1000.0	4100.7	0.4	5308	0.059	0	35	0	216.5	154.8	5.1	217.5	6.6	9.1	0.49	1	0.142	3.8
早班										1615.7			1519.7			1773.8							
运行正常										运行正常													
中班										运行正常													
晚班										运行正常													
统计		进水流量累积m³	出水流量累积m³	进水量m³	出水量m³	出水量m³	自来水用量m³	除磷剂用量kg	次氯酸钠用量kg														
早班		6667424.7	5929126	5071.5	4909.2	4909.2	27	6000															

早班值班: [Signature] 中班值班: [Signature] 晚班值班: [Signature] 审核人: [Signature]